

# THREADED SOCKET TEST POINT

(ABSo38 - 25mm)



This component is used when the system needs to be smoke tested. The threaded plug is removed, which allows the smoke generator to gain access to the system. Simply replace after use.

## Installation Instructions:

Use the correct solvent Plusbond 3019. Do not paint. Keep pipe clean and free from dust. Do not install in direct sunlight. Only install with approved pipe. Do not use solvents to clean, only soapy water.

**PART NO.:**  
ABSo38 - 25

**PIPE COLOUR:**  
Red

**OPERATING TEMP:**  
- 40 c to 70 c'

**WEIGHT:**  
17.6g

**FITTINGS COLOUR:**  
Red

**DIAMETER TOLERANCE:**  
+ / - 0.15mm'

**WALL THICKNESS:**  
2mm

